

DIVISION OF INDUSTRY SERVICES
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658
TTY: Contact Through Relay

Scott Walker, Governor Dave Ross, Secretary

March 9, 2016

WATER RIGHT INCORPORATED - CARESOFT CARESOFT KURT GRUETT 190 PROSPECT COURT APPLETON WI 54914

Re: Description: WATER TREATMENT DEVICE - SOFTENER/CATION EXCHANGE

Manufacturer: WATER RIGHT INCORPORATED - CARESOFT

Product Name: (trans id) CARESOFT ELITE

Model Number(s): CSE-844TW, CSE-1044TW, CSE-1054TW AND CSWE-1354TW

Product File No: 20160074

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of March 2021.

This approval is contingent upon compliance with the following stipulation(s):

- This product has undergone sufficient testing to document the product's ability to reduce only those
 contaminants and/or substances as specified in this approval letter when the product is installed and maintained
 in strict accordance with the manufacturer's published instructions.
- Where the Department of Natural Resources (DNR) has jurisdiction, a written approval may be required prior to installation of this product in a water supply system to reduce the concentration of a contaminant that exceeds the primary drinking water standards contained in ch. NR 809, Wis. Admin. Code, the enforcement standards contained in ch. NR 140, Wis. Admin. Code, or for a water supply system that is subject to a written advisory opinion by the DNR. For more information contact the DNR Section of Private Water Systems, P.O. Box 7921, Madison, WI 53707, telephone (608) 267-9787.
- If these approved devices are modified or additional assertions of function or performance are made, then this
 approval shall be considered null and void, unless the change is submitted to the department for review and the
 approval is reaffirmed.
- These cation exchange water softeners shall be sized, installed, programmed and maintained such that wastewater volumes, total dissolved solids and chloride discharges are minimized.

Based on testing data submitted to and reviewed by the department, this approval recognizes that these plumbing products will reduce the concentration of contaminants as specified on pages 1 through 2 of this letter.

SBD-10564-E (N.10/97) File Ref: 16007401.DOC

Water Right Incorporated - CareSoft

March 9, 2016 Page 2 of 2

Product File No.: 20160074

WATER SOFTENING CAPABILITIES PRODUCT FILE NUMBER 20160074 TABLE 1 OF 1

Model Numbers	Capacities*						Flow Rates vs.
CareSoft Elite Twin	Rating 1		Rating 2		Rating 3		Pressure Losses
Metered	Grains	Pounds	Grains	Pounds	Grains	Pounds	gpm @ psig
CSE-844TW	15,600	3.0	21,600	6.0	25,600	9.0	11.4 @ 15
CSE-1044TW	23,600	6.0	28,400	9.0	32,000	15.0	17.1 @ 15
CSE-1054TW	35,400	9.0	44,400	15.0	48,800	21.0	14.3 @ 15
CSE-1354TW	53,000	12.0	64,200	18.0	72,800	24.0	18.5 @ 15
CSE-1465TW	60,000	18.0	75,000	30.0	90,000	45.0	27.0 @ 25
CSE-1665TW	80,000	24.0	100,000	40.0	120,000	60.0	29.0 @ 25

^{*} The softener capacity rating is based on grains of hardness, due to calcium and magnesium cations, removed (as calcium carbonate) while producing soft water between successive regenerations and is related to the pounds of salt required for each regeneration. The tests run to generate the data for table 1 were conducted in accordance with NSF Standard 44.

These devices are also approved to treat $\leq 1.0 \text{ mg/l}$ of dissolved iron (Fe⁺²) or dissolved manganese (Mn⁺²). When dissolved Fe⁺² or Mn⁺² is present in the raw water, each mg/l of Fe⁺²/Mn⁺² shall be counted as 5 grains per gallon (gpg) of hardness for the purposes of programming the valve.

This device was tested under controlled laboratory, or field, conditions. The actual performance of this device for a specific end use installation will vary from the tested conditions based on local factors such as water pressure, water temperature and water chemistry.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter
Environmental Engineer - Plumbing Product Reviewer
Depart of Safety and Professional Services
Division of Industry Services
Bureau of Technical Services
(608) 267-1401 Phone
(608) 267-9723 Fax
glen.schlueter@wi.gov E-mail